



BELL HOLES SHALL BE KEPT
TO A MINIMUM SIZE

PIPE TO BE SUPPORTED FOR
ENTIRE LENGTH WITH NO
BLOCKING ALLOWED

DEPARTMENT OF PUBLIC WORKS
CITY OF ROCHESTER, MINNESOTA

INSTALLATION DETAIL

Douglas C. Roney
RPO - WATER UTILITY

Paul W. Finner
DIRECTOR

SHT 1 OF 1 SHTS

DATE REVISED
10/1/97

PLATE NO.
6-09

REV.
A